



CLIENT: International Cellulose
 PO Box 450006
 Houston, TX 77245

Attn: Joe Witt

Test Report No: 337856-3R	Date: July 25, 2005
----------------------------------	----------------------------

SUBJECT: ASTM C 739-97, Section 11 for Fungus Resistance of Cellulose Insulation.

REFERENCE: Letter.

SAMPLE ID: One bag of Celbar Wall Spray Insulation was received on 6/10/05 in good condition.

PROCEDURE: The Fungus Resistance of the material was tested for compliance with the Amended CPSC Standard and 16 CFR 1209 and ASTM C 739-91, Section 11.

TEST DATE: 7/18/05.

RESULTS: Sample Fungal Growth as Compared to Control Fungal Growth


<u>Sample</u>	<u>Less Growth</u>	<u>Same Growth</u>	<u>More Growth</u>	<u>Comments</u>
1	0	-	-	No growth observed
2	0	-	-	No growth observed
3	0	-	-	No growth observed

Requirement: 0.12, minimum


CONCLUSION: The material does comply with the Amended CPSC Standard, and 16 CFR 1209 and ASTM C 739-91.

CERTIFICATION: The tests reported here were conducted under the continuous direct supervision of SGS U.S. Testing Company Inc., Tulsa, OK.

**SIGNED FOR AND ON BEHALF OF
 SGS U.S. TESTING COMPANY INC.**



bk Jeffrey Simmons
 Manager Laboratory Operations



Dale E. Holloway
 Branch Manager Laboratory Operations

This report is issued by SGS U.S. Testing Company Inc. under its General Conditions for Testing Services, as printed on reverse side. SGS U.S. Testing's responsibility under this report is limited to proven negligence and will in no case be more than the amount of the testing fees. Except by special arrangement, samples are not retained by SGS U.S. Testing for more than 30 days. The results shown on this test report refer only to the sample(s) tested unless otherwise stated, under the conditions agreed upon. Anyone relying on this report should understand all of the details of the engagement. Neither the name, seals, marks nor insignia of SGS U.S. Testing may be used in any advertising or promotional materials without the prior written approval of SGS U.S. Testing. The test report cannot be reproduced, except in full, without prior written permission of SGS U.S. Testing Company Inc.